



Transferring Energy Efficiency in Mediterranean Schools (TEESCHOOLS)

6th International Conference on Renewable Energy
Sources & Energy Efficiency – New challenges

University of Cyprus, Nicosia

01 - 02/11/2018



ΕΝΕΡΓΕΙΑΚΟ ΓΡΑΦΕΙΟ
— ΚΥΠΡΙΩΝ ΠΟΛΙΤΩΝ —

Maria Achilleos

Architectural Engineer, M.Sc.





Contents



1. Introduction
2. Methodology
3. Selected schools
4. Results [Suggested implementations]
5. NZEB Feasibility
6. Thermal comfort assessment [on-going]
7. Next steps
8. Conclusions



Contents



1. Introduction
2. Methodology
3. Selected schools
4. Results [Suggested implementations]
5. NZEB Feasibility
6. Thermal comfort assessment [on-going]
7. Next steps
8. Conclusions



The Cyprus Energy Agency



- Non Governmental, Non profit organization
- Officially established on the 09/02/2009



Vision

*“to contribute actively to the conservation of energy resources,
protecting the environment and contributing to the quality of life!”*

Specific objectives

“Promotion of renewable energy sources, sustainable transport, improvement of energy efficiency and contribution to the mitigation and adaptation to climate change”

How we do this


Training Seminars - Exams and certification - Raising Awareness - GPP Supporter - Technical studies - Covenant of Mayors - **European projects**



The TEESCHOOLS project



...in simple words



*"Development of a set of tools and methodologies to help Municipalities and buildings' managers conduct energy audits in an easy and cost effective way." –
is NZEB scenario feasible?*

→ 5 schools were selected in Cyprus based on pre-defined criteria



The TEESCHOOLS project



Key outputs

- **Integrated set of tools supporting energy efficiency management in schools** with carbon footprint calculator; best practices database for NZEB energy renovation of school buildings; financial solutions and schemes for energy efficiency;
- **Pilot applications at school buildings:** energy audits, renovation plans, calculation of carbon footprint of the renovation activities, development of energy service models and financing schemes.
- **E-learning and face-to-face training** of Regional and Municipal technical staff, energy managers and students.
- **Development of policy recommendations** and integration of project outputs to city plans.



Energy Audits – Experts' Team



Coordinator

Savvas Vlachos

Certified Energy Auditor for Buildings and Industries

External
Partners

Dr Apostolos Michopoulos

Energy Audits Coordinator (External – Certified Energy Auditors' Trainer)

Orestis Kyriakou

Certified Energy Auditor
for Buildings & qualified
expert for the issue of
EPCs

CEA

Marios Petrakkas

Electrical Engineer –
Certified Energy Auditor
for Buildings and
Industries

Giannis Kanaris

Mechanical Engineer -
Certified Passivhaus
Designer

Maria Achilleos

Architectural Engineer –
Qualified expert for the
issue of EPCs

Myrto Skouroupathi

Environmental Engineer




Contents



1. Introduction
2. Methodology
3. Selected schools
4. Results [Suggested implementations]
5. NZEB Feasibility
6. Thermal comfort assessment [on-going]
7. Next steps
8. Conclusions



Methodology



STEP – BY – STEP:

Preliminary contact – Purpose of the energy audit

- Established by the project and the needs of the local schools

Start-Up meeting

- With the school users and managers – role, needs, timeframe, clarifications

Data collection

- Data (energy bills and architectural/technical drawings) have been collected before the on-site visits by the competent bodies.

Current state analysis

- Dynamic energy simulations have been established for calibrating the current state analysis (IES-VE)

Parallel Actions

- *Includes the measurements for 2 weeks (at least) for electricity consumption & for temperature and relative humidity in selected classrooms and the efficiency of the boiler.*

Auditing and Measurements on-site

- On-sites visits have been established for additional data collection & validation of the acquired data for each school building

CYS EN 16247-1:2012 Standard

Identification of the possible energy upgrade measures

- For each school, various scenarios were examined and analyzed from technical perspective

Evaluation of measures


- All the selected scenarios were evaluated based on their energy and economic savings – Technoeconomic feasibility – LCC.

Delivery of the energy report and user training

- Energy reports were established for each participating school – they are currently delivered along with further training on energy matters



Methodology




CYS EN 16247-1:2012 Standard

SCOPE OF THE ENERGY AUDIT:

- Building's Envelope
- Heating system
- Cooling System [where applicable]
- Lighting system
- Auxiliary infrastructure and equipment
- Renewable Energy System [where applicable]



Methodology



CYS EN 16247-1:2012 Standard

EQUIPMENT USED



FLIR E30 - Infrared Thermal Imaging Camera



EXTECH RHT10 & RHT20 - Humidity and Temperature Datalogger



Kimo Kigaz 100 Combustion Flue Gas Analyzer



Fluke 1735 - Power meter for conducting energy studies and basic power quality logging





Contents



1. Introduction
2. Methodology
3. Selected schools
4. Results [Suggested implementations]
5. NZEB Feasibility
6. Thermal comfort assessment [on-going]
7. Next steps
8. Conclusions



Selected Schools



Hadgigeorkakis Kornesios, Primary School in Aglantzia, Nicosia [CZ-2]

Treated Floor Area: 1,502 m²

Heated Floor Area: 1,286 m²

221 Students | 250 Users

Use: September - June

Typical Time schedule: 07:45 – 13:05 | Extra Hours: 13:05 – 21:30

Construction Years: A. 1968, B. 2004, C. 2014

Envelope Material: Varying in accordance to the year of construction

Heating System: Central system with oil-fired burner

Cooling System: Split units in administrative spaces and special education classrooms

Lighting System: Mainly Fluorescent Tubes

Typical Classroom Equipment: Desktop PC, Smart Board, Projector, Speakers



Selected Schools



3rd Primary School Ayios Georgios – Lakatamia, Nicosia [CZ-2]

Treated Floor Area: 2,024 m²

Heated Floor Area: 1,831 m²

379 Students | 415 Users

Use: September - June

Typical Time schedule: 07:45 – 13:05 | Extra Hours: 13:05 – 21:30

Construction Years: A. 1987, B. 2008, C. 2014

Envelope Material: Varying in accordance to the year of construction

Heating System: Central system with oil-fired burner

Cooling System: Split units in administrative spaces, labs and special education classrooms

Lighting System: Mainly Fluorescent Tubes

Typical Classroom Equipment: Desktop PC, Smart Board, Projector, Speakers



Selected Schools



Ayios Andreas Primary School (CA and CB), Nicosia [CZ-2]





Selected Schools



Ayios Andreas Primary School (CA and CB), Nicosia [CZ-2]

Treated Floor Area: 1,958 m²

Heated Floor Area: 1,757 m²

269 Students | 299 Users

Use: All year

Typical Time schedule: 07:45 – 13:05 | Extra Hours: 13:05 – 20:30

Construction Years: A. 1989, B. 2008 + Partial maintenance works in 2008 and 2013

Envelope Material: Stone and wooden/iron windows, and brick, reinforced concrete, alum, frames

Heating System: Central system with oil-fired burner

Cooling System: Split units in admin. spaces, labs, special education class. and multipurpose room

Lighting System: Mainly Fluorescent Tubes

Typical Classroom Equipment: Desktop PC, Smart Board, Projector, Speakers



Selected Schools



Livadia Primary School – Liadia, Larnaka (CB) [CZ-1]

Treated Floor Area: 960 m²

Heated Floor Area: 792 m²

203 [250] Students | 246 [278] Users

Use: September - June

Typical Time schedule: 07:45 – 13:05 | Extra Hours: 13:05 – 21:00

Construction Years: A. 1946, B. 1970 + Partial maintenance works in 2008 and 2017

Envelope Material: Varying in accordance to the year of construction

Heating System: Central system with oil-fired burner

Cooling System: Split units in administrative spaces and special education classroom

Lighting System: Mainly Fluorescent Tubes

Typical Classroom Equipment: Desktop PC, Smart Board, Projector, Speakers, Fans



Selected Schools



Voroklini Primary School – Voroklini, Larnaka [CZ-1]

Treated Floor Area: 1,663 m² [up to 2018]

Heated Floor Area: 1,534 m² [up to 2018]

400 Students | 438 Users

Use: All Year

Typical Time schedule: 07:45 – 13:05 | Extra Hours: 13:05 – 21:00

Construction Years: A. 1964, B:1974-1979, C:1985, D:1991-2001, E:2004-2009, F:2015, G:2018

Envelope Material: Varying in accordance to the year of construction

Heating System: Central system with oil-fired burner

Cooling System: Split units in administrative spaces, special education classroom and labs

Lighting System: Mainly Fluorescent Tubes

Typical Classroom Equipment: Desktop PC, Smart Board, Projector, Speakers, Fans




Contents



1. Introduction
2. Methodology
3. Selected schools
4. Results [Suggested implementations]
5. NZEB Feasibility
6. Thermal comfort assessment [on-going]
7. Next steps
8. Conclusions



Results






Results [Primary energy per sq.m.]



Annual Average Data – Energy Consumption






Results [Electricity & Heating per sq.m.]



Annual Average Data – Electricity and Oil Consumption

Average [Results]
17.25
29.57






Results [Electricity consumption breakdown]




H. Kornesios

- Lighting
- Office Equipment
- Kitchen Equipment
- Other




Lakatamia

- Lighting
- Office equipment
- Kitchen equipment
- Cooling
- Other




Ayios Andreas

- Lighting
- Office Equipment
- Kitchen Equipment
- Cooling (AC+Fans)
- Other (pumps)




Livadia

- Lighting
- Office Equipment
- Kitchen Equipment
- Cooling (Ac)
- Ventilation
- Other (pumps)



Voroklini

- Lighting
- Office Equipment
- Kitchen Equipment
- Cooling (Ac)
- Ventilation
- Other (pumps)







Results [Energy Cost & Carbon Emissions]



Annual Average Data – Energy Cost



Annual Average Data – Carbon Emissions





Results [Suggested implementations]



A/A	Description	Average Energy Savings (kWh _{el} /th/year)	Average Primary Energy Savings (KWh _{pr} /year)	Average Carbon Emission Savings (kgCO ₂ /year)	Average Initial Cost (€)	Cost per primary energy saved (€/KWh _{pr})
A	Installation of LED lighting	8,203.40	22,149.18	6,513.58	5,088.40	0.22
B	Installation of PV system [capacity varies]	11,566.80	31,230.20	9,184.24	9,533.80	0.30
C	Insulation of the roofs [3 schools]	10,383.33	12,834.33	3,228.33	47,313.33	3.68
D	Insulation or replacement of the heating distribution pipelines	6,238.40	6,862.40	1,659.60	1,389.80	0.20
E	Adjustment and/or maintenance of the boiler [3 schools]	4,306.33	4,737.33	867.50	200.00	0.04
F	NZEB Scenario	39,872.28	76,838.92	21,489.33	314,563.20	4.09
G	Installation of external shading Passive strategies	Should be studied individually				
E	Behavioural Change	Seems to have a great impact on the energy consumption of schools				

Installation of A/C units where is needed ?



Contents



1. Introduction
2. Methodology
3. Selected schools
4. Results [Suggested implementations]
5. NZEB Feasibility
6. Thermal comfort assessment [on-going]
7. Next steps
8. Conclusions



State of the Art - Cyprus




	Minimum Energy Efficiency Requirements					nZEB
	21.12.2007 - 31.12.2010	01.01.2010 - 10.12.2013	11.12.2013 - 29.10.2015	30.10.2015 - 31.12.2016	01.01.2017 - 31.12.2020	01.01.2019 (P.B.) 01.01.2021 and afterwards
	Decree 568/2007	Decree 446/2009	Decree 432/2013	Decree 359/2015	Decree 119/2016	Decree 366/2014
Ranking - Class	-	≥ B	≥ B	≥ B	≥ B	A
U value - Walls	≤ 0.85 W/m².K	≤ 0.85 W/m².K	≤ 0.72 W/m².K	≤ 0.72 W/m².K	≤ 0.40 W/m².K	≤ 0.4W/m².K
U value – Horizontal structural elements	≤ 0.75 W/m².K	≤ 0.75 W/m².K	≤ 0.63 W/m².K	≤ 0.63 W/m².K	≤ 0.40 W/m².K	≤ 0.4W/m².K
U value of a ground (over non - heated spaces)	≤ 2.0 W/m².K	≤ 2.0 W/m².K	≤ 2.0 W/m².K	≤ 2.0 W/m².K	-	-
U value of the windows	≤ 3.8 W/m².K	≤ 3.8 W/m².K	≤ 3.23 W/m².K	≤ 3.23 W/m².K	≤ 2.90 W/m².K	≤ 2.25 W/m².K
U value – Mean (Walls & Windows)	-	1.3 W/m².K	≤ 1.3 W/m².K	≤ 1.3 W/m².K	≤ 1.3 W/m².K	-
Maximum consumption of primary energy	-	-	-			100 kWh/m².year 125 kWh/m².year
Maximum energy demand for heating	-	-	-			15 kWh/m².year
Maximum window shading coefficient	-	-	0.63	0.63	0.63	0.63
Maximum power of lighting installations at office buildings					10 W / m²	10 W / m²
Share of RES in primary energy consumption	-	Solar Thermal & PVs Providence	Solar Thermal & PVs Providence	Solar Thermal & PVs Providence	25% (Detached) 3% (Apartments) 7% (Non Residential)	25%



NZEB Feasibility



Agios Andreas Primary School (Cycle A & B) – Nicosia




Index	Value [€]
LCC _A	- 207,609
LCC _B	- 428,318
NCF	- 220,710



NZEB Feasibility – Subsidy needed



NZEB Scenarios





Contents



1. Introduction
2. Methodology
3. Selected schools
4. Results [Suggested implementations]
5. NZEB Feasibility
6. Thermal comfort assessment [on-going]
7. Next steps
8. Conclusions



Thermal Comfort Assessment



- Measures VS Simulated Data

In order to assess the internal conditions of the classrooms, and consequently thermal comfort levels, besides the questionnaires which can be subjective, Data Loggers have been used to record the temperature and the humidity in the rooms. Those loggers were placed for 2 weeks in 2 classrooms, the one that is performing the best and then one that is performing the worst, in accordance to the school's users.


The loggers were taking measurements at a time step of half an hour. Those measurements were compared with the energy model in order to validate its accuracy. As it seems from the next graphs, the model's results are close to the measured ones, therefore this allows the evaluation of other classrooms/spaces where loggers were not placed [other scenarios were tested as well].



Thermal Comfort Assessment



1st FLOOR




GROUND FLOOR




Thermal Comfort Assessment



Results for the worst performing classroom in accordance to the users – Winter [06/02]



Internal temperature [12 - 21.5°C]



PMV [-1.8 - -0.15]

Based on the EN 15251:2012 Standard

- Baseline Scenario
- nZEB Scenario
- Teaching period


Windows open for ventilation – Common practise




Thermal Comfort Assessment



Results for the best performing classroom in accordance to the users – Winter [06/02]



Εσωτερική Θερμοκρασία [13,6 - 21.2°C]



PMV [-1.2 - -0.10]

Based on the EN 15251:2012 Standard

- Baseline Scenario
- nZEB Scenario
- Teaching period


Windows open for ventilation – Common practise




Thermal Comfort Assessment



Results for the worst performing classroom in accordance to the users – Summer [06/06]



Εσωτερική Θερμοκρασία [21,4 - 29.2°C]



PMV [+0,40 - +1.65]

Based on the EN 15251:2012 Standard

- Baseline Scenario
- nZEB Scenario
- nZEB Scenario – Night Cooling
- Teaching period


End of night cooling




Thermal Comfort Assessment



Results for the best performing classroom in accordance to the users – Summer [06/06]



Εσωτερική Θερμοκρασία [21,4 - 29.2°C]



PMV [+0,45 - +1.60]



Based on the EN 15251:2012 Standard

- Baseline Scenario
- nZEB Scenario
- nZEB Scenario – Night Cooling
- Teaching period

End of night cooling





Passive strategies



↖ Sun Diagram [21.06 & 21.12]

Wind Rose [Summer - Yearly] ↘





Contents



1. Introduction
2. Methodology
3. Selected schools
4. Results [Suggested implementations]
5. NZEB Feasibility
6. Thermal comfort assessment [on-going]
7. Next steps
8. Conclusions



Next steps



- Thermal Comfort Assessment [finalisation] - *out of the scope of the programme*
- Passive strategies – Suggestions based on Analysis
- Presentation of the results to the schools
- Guidance to ensure funding when possible
- Educational Presentations
- Behavioural change



Contents



1. Introduction
2. Methodology
3. Selected schools
4. Results [Suggested implementations]
5. NZEB Feasibility
6. Thermal comfort assessment [on-going]
7. Next steps
8. Conclusions



Conclusions



- Energy consumption in the majority of primary school buildings seems to be **low** when compared to other types of non-residential buildings -or other educational buildings from the participating countries-, therefore the energy saving potential is considered to be limited.
 - Limited hours of operation [Half day, Morning hours, Closed in the summer, Easter holidays, Christmas holidays]
 - Without active cooling usually [Design Templates - Technical Services of the Ministry of Education and Culture]
 - They are not proposed to be implemented by an Energy Performance Contract (EPC). Therefore, it is not proposed to involve an Energy Services Company (ESCO), but to finance the interventions themselves from the School Board's budget.
- The majority of **large scale energy upgrade measures** have negative economic indicators and their economic viability can only be ensured by a subsidy (ie. state aid).
- In addition to the economic indicators, the benefits of thermal comfort, which derives from the implementation of large-scale energy upgrades, should be taken into consideration.
- When adopting the NZEB criteria for the energy upgrading of the school, passive strategies for cooling and heating should be also examined for extra energy savings and for the improvement of comfort conditions.

ECONOMIC CRITERIA ↔ ENERGY UPGRADING ↔ EDUCATIONAL CRITERIA

Food for thought: *"How does the lack of thermal comfort in schools affects learning?*

What does it cost to the Cyprus economy? "



Thank you!

CONTACT:

Maria Achilleos | Architectural Engineer: maria.achilleos@cea.org.cy

Cyprus Energy Agency

Address: 10-12 Lefkonos St., 1011 Nicosia, Cyprus

Phone Nº: 00357 22 66 77 16

Fax: 00357 22 66 77 36

Webpage: www.cea.org.cy

Facebook: Cyprus Energy Agency

Twitter: cyenergyagency



ΕΝΕΡΓΕΙΑΚΟ ΓΡΑΦΕΙΟ
— ΚΥΠΡΙΩΝ ΠΟΛΙΤΩΝ —



Project co-financed by the European
Regional Development Fund